



DuPont™ ISCEON® 9 Series
REFRIGERANTS

Technical Information

**Retrofit Guidelines for
DuPont™ ISCEON® M099
Refrigerant**



The miracles of science™

Retrofit Guidelines for
DuPont™ ISCEON® MO99 Refrigerant

Table of Contents

	<i>Page</i>
Introduction	1
Summary - Steps to Retrofit	1
Important Safety Information	2
Flammability	2
General Retrofit Information	2
Lubricant	2
Filter Drier.....	2
Elastomeric Seals/ Gaskets etc.	2
System Modifications.....	3
System Superheat.....	3
System Oil Management	3
Refrigerant Recovery Information.....	3
Expected Performance After Retrofit.....	3
Detailed Retrofit Procedure for R22 Systems to ISCEON® MO99	4
Pressure-Temperature Charts	6
How to Read the Pressure/Temperature Tables	6
How to Determine Suction Pressure, Superheat, and Subcool	6
Retrofit Checklist for R22 (ISCEON® MO99)	7
System Data Sheet	9
Appendix	11
PT Charts	11

Introduction

DuPont™ ISCEON® MO99 is a non-ozone-depleting HFC Refrigerant designed to replace R22 in existing direct expansion (DX) systems where the expansion device capacity is very closely matched to the system capacity (>80%). This has been frequently found to be the case with many water chillers and therefore ISCEON® MO99 is the recommended retrofit option for DX water chillers.

Field experience has shown that ISCEON® MO99 provides performance that meets customer requirements in most properly retrofitted systems. ISCEON® MO99 provides similar cooling capacity and energy efficiency to R22 in most systems, while operating at significantly lower compressor discharge temperature. Actual performance depends on system design and operating conditions.

ISCEON® MO99 is compatible with traditional and new lubricants; in most cases no change of lubricant type during retrofit is required. Oil return is determined by a number of operating and design conditions – in some systems with complex piping configurations or liquid reservoirs on the low pressure side, POE may need to be added. Minor equipment modifications (e.g., seal replacement) or expansion device adjustments may be required in some applications. **Systems using ISCEON® MO99 are easy to service. For most systems, should a refrigerant loss occur, the charge can be completed without the need to remove any residual refrigerant, and the system will then operate normally. The cause of the refrigerant loss should be investigated and corrected as soon as is possible.**

Note: When servicing critically charged systems, all of the refrigerant charge should be removed. This is the same practice recommended for HCFC-22.

General Considerations

The use of ISCEON® MO99 in the EU and EEA member countries is regulated under the terms of the Regulation 842/2006 (known as the “F Gas Regulation”), which requires regular leakage testing for systems using the designated substances.

Summary - Steps to Retrofit

The following provides a summary of the basic retrofit steps for ISCEON® MO99.

(Detailed discussion of each step is provided in this bulletin.)

1. Establish baseline performance with existing refrigerant. (See retrofit checklist (attached))
2. Remove all the old (R22 or other) refrigerant from the system into a recovery cylinder. Weigh the amount removed.
3. Replace the filter drier and critical elastomeric seals/gaskets.
4. Evacuate system and check for leaks.
5. Charge with ISCEON® MO99.
 - Remove liquid only from charging cylinder.
 - The initial charge amount should be approximately 85% of the standard charge for R22. The final charge amount will be approximately 95%.
6. Start up system, determine suction line superheat and adjust TXV and/or charge size if necessary to achieve the optimum value.
7. Monitor oil levels in compressor. Add oil as required to maintain proper levels
8. Label system showing the refrigerant (and any replacement lubricant) used. Update system log-book.

Retrofit Complete

Important Safety Information

Like CFCs and HCFCs, ISCEON® 9 Series refrigerants are safe to use when handled properly. However, any refrigerant can cause injury or even death when mishandled. Please review the following guidelines before using any refrigerant.

- Do not work in high concentrations of refrigerant vapors. Always maintain adequate ventilation in the work area. Do not breathe vapors. Do not breathe lubricant mists from leaking systems. Ventilate the area well after any leak before attempting to repair equipment.
- Do not use handheld leak detectors to check for breathable air in enclosed working spaces. These detectors are not designed to determine if the air is safe to breathe. Use oxygen monitors to ensure adequate oxygen is available to sustain life.
- Do not use flames or halide torches to search for leaks. Open flames (eg. Halide detection torches, or brazing torches) can release large quantities of acidic compounds in the presence of all refrigerants, and these compounds can be hazardous. Halide torches are not effective as leak detectors for HFC refrigerants; they detect the presence of Chlorine, which is not present in ISCEON® MO99, and consequently, these detectors will not detect the presence of this refrigerant. Use an electronic leak detector designed to find the refrigerants you are using.

If you detect a visible change in the size or color of a flame when using brazing torches to repair equipment, stop work immediately and leave the area. Ventilate the work area well and stop any refrigerant leaks before resuming work. These flame effects may be an indication of very high refrigerant concentrations, and continuing to work without adequate ventilation may result in injury or death.

Note: Any refrigerant can be hazardous if used improperly. Hazards include liquid or vapor under pressure, and frostbite from the escaping liquid.

Overexposure to high concentrations of refrigerant vapor can cause asphyxiation and cardiac arrest. Please read all safety information before handling any refrigerant.

Refer to the ISCEON® MO99 Material Safety Data Sheet (MSDS) for more specific safety information. DuPont Safety Bulletin AS-1 also gives additional information for safe handling of refrigerants.

Flammability

ISCEON® MO99 is non-flammable in air under normal conditions. However, this product when mixed with high concentrations of air or oxygen under elevated pressure can become combustible in the presence of an ignition source. This product should not be mixed with air to check for system leaks.

General Retrofit Information

Lubricants

Lubricant selection is based on many factors, including compressor wear characteristics, material compatibility, and lubricant/refrigerant solubility (which can affect oil return to the compressor). ISCEON® MO99 is compatible with traditional and new lubricants – in most retrofit situations with direct expansion systems no change of oil type is required.

Field experience has shown that ISCEON® MO99 will work successfully with the existing mineral (or alkylbenzene) oil in most DX systems. In systems where oil return is a potential concern, such as systems where the suction line accumulator acts as a low pressure receiver, replacement of all, or part (~30%) of the compressor oil charge with an OEM approved polyol ester oil is recommended.

Filter Drier

Change the filter drier during the retrofit. This is a routine system maintenance practice. There are two types of filter driers commonly used, solid core and loose filled. Replace the drier with the same type currently in use in the system. The drier label will show which refrigerants can be used with that drier. Select a drier specified to work with HFC refrigerants. (Many driers sold today are “universal” – they will work with most fluorocarbon refrigerants.)

Elastomeric Seals/ Gaskets etc.

R22, and to a lesser extent R22 containing refrigerant blends, interacts relatively strongly with many elastomers causing significant swelling and often, over time, a measurable increase in hardness, etc. ISCEON® MO99 does not have such a strong effect on those elastomers commonly used in seals in refrigeration systems. A consequence of this is that, when replacing R22 (and, to a lesser extent, R22 containing blends) with ISCEON® MO99 in a system retrofit, it is possible for leaks to occur at Elastomeric seals that are exposed to the refrigerant. (This is not a problem attributable to the use of ISCEON® MO99. Such seal leaks have been reported when replacing R22 with other HFC refrigerants such as R407C or R404A.)

Leaks do not occur in every system retrofitted and, in practice, it is difficult to predict whether such leaks will occur.

(As a rule of thumb the older the system, the higher the probability that leaks will be observed after a retrofit.)

As a consequence it is recommended to change any system-critical seals (those which would require removal of the refrigerant charge to allow seal replacement e.g., liquid receiver, refrigerant high-pressure side, etc.) as a matter of course during the retrofit and to have spare seals for other components available during restart of the system. A rigorous leak check regime pre- and post- retrofit will minimize any refrigerant losses. All seals should be checked including manual valves, schrader valves, solenoid valves, sight glasses, electrical cable sealing grommets (on compressors), mechanical seals on open drive compressors, etc. Obviously any seals found to be leaking before the retrofit takes place should be replaced during the retrofit.

System Modifications

The compositions of the ISCEON® MO99 refrigerant has been selected to provide performance comparable to R22 in terms of both capacity and energy efficiency. As a result, minimal system modifications are anticipated with retrofitting.

ISCEON® MO99 is a near-azeotrope. The vapor composition in the refrigerant cylinder is different from the liquid composition. For this reason, ISCEON® MO99 should be transferred from the container from the liquid phase during system charging (or when transferring from one container to another).

In general, ISCEON® MO99 refrigerant is not recommended for use in centrifugal compressor systems or for chillers with flooded evaporators. Direct expansion systems with low pressure receivers may be retrofitted using ISCEON® MO99 but a single oil change to a POE oil of the same viscosity as the original oil type is required to ensure adequate oil management for this system configuration.

Note: ISCEON® MO99 should not be mixed with other refrigerants or additives that have not been clearly specified by DuPont or the system equipment manufacturer. Mixing this refrigerant with CFC or HCFC refrigerants, or mixing two different alternative refrigerants, may have an adverse effect on system performance. "Topping off" a CFC or HCFC refrigerant with any Suva® or ISCEON® 9 Series refrigerant is strictly not recommended.

System Superheat

Desired system performance after a retrofit with DuPont™ ISCEON® MO99 requires correct setting of the system superheat. This is discussed in the detailed retrofit procedures given below.

System Oil Management

In many situations, systems retrofitted with ISCEON® MO99 have operated routinely using the mineral oil or Alkyl benzene that was used with the original HCFC refrigerant. With complex systems, in a small number of cases, the oil may not return consistently to the compressor.

It is important that oil levels in the compressors be monitored during initial operation with the ISCEON® MO99. If the oil level falls below the minimum allowed, top up the oil to the minimum level with the existing oil type. Do not fill to maximum as the level may rise again.

Should the oil level fall continuously, or suffer large oscillations during an operating cycle, addition of POE lubricant has proven effective in restoring adequate oil return rates. POE lubricant should be progressively added to the system. An initial addition of 10-30% (of the total oil charge) should be made. This should be followed by further small increments until the oil level returns to normal.

It is important to ensure that, when adding POE oil to the system, the oil level (immediately after addition) is kept below the system mid-point (e.g. mid-sight glass) oil level.

It is also important to keep accurate records of how much oil is added to avoid over-filling.

Refrigerant Recovery Information

Most recovery or recycle equipment used for R22, can be used for ISCEON® MO99. Use standard procedures to avoid cross contamination when switching from one refrigerant to another. Most recovery or recycle machines can use the same compressor oil that was used for the HCFC refrigerant. However, some modifications may be necessary, such as a different kind of drier or a different moisture indicator. Consult the equipment manufacturer for specific recommendations.

Expected Performance After Retrofit

Table 1 shows approximate system performance changes following a retrofit and are general guidelines for system behavior. These values are based on field experience,

calorimeter testing and thermodynamic property data; and assume equal compressor efficiency.

Cooling capacity and energy efficiency depend greatly on system design, operating conditions and the actual condition of the equipment. ISCEON® MO99 provides similar cooling capacity and energy efficiency to R22 in most systems while operating at significantly lower compressor discharge temperature. Actual performance depends on system design and operating conditions.

Table 1

ISCEON® MO99 Performance Compared to R22 in a DX Water Chiller

Performance with subcooling based on thermodynamic cycle calculations from calorimeter data and do not include heat transfer effects

	Air Conditioning (Water Chiller)	Air Conditioning (Water Chiller)
	+2°C evaporator 40°C condenser 20°C return gas 8K liquid subcooling	+4°C evaporator 49°C condenser 20°C return gas 8K liquid subcooling
	[difference vs. R22]	[difference vs. R22]
Discharge Temperature / K	-19	-21
Discharge Pressure / kPa	+14	+32
Evaporator Pressure / kPa	-25	-29
Refrigeration Cooling Capacity / %	-3%	-6%
Energy Efficiency / %	0%	-1%

“+” represents an increase and “-” represents a decrease for ISCEON® MO99 vs. R22

Detailed Retrofit Procedure for R22 in Direct Expansion Medium and Low Temperature Refrigeration Systems, Residential and Commercial Air-Conditioning

(Refer to the retrofit checklist on pages 7 and 8 of this bulletin)

1. Establish baseline performance with R22. Collect system performance data while R22 is in the system. Check for correct refrigerant charge and operating conditions. The baseline data of temperatures and pressures at various points in the system (evaporator, condenser, compressor suction and discharge and calculation of superheat and subcool.) at normal operating conditions will be useful when optimizing operation of the system with the ISCEON® MO99. A System Data Sheet is included at the back of this bulletin to record baseline data.

2. Remove the existing R22 refrigerant from the system into a recovery cylinder. The existing charge should be removed from the system and collected in a recovery cylinder using a recovery device capable of pulling 10–15 in Hg vacuum (50–65 kPa absolute). If the recommended charge size for the system is not known, weigh the amount of refrigerant removed. The initial quantity of ISCEON® MO99 to charge to the system can be estimated from this amount. (See step 5). Ensure that any residual refrigerant dissolved in the compressor oil is removed by holding the system under vacuum. Break the vacuum with dry nitrogen.

3. Replace the filter drier and critical elastomeric seals/gaskets etc

It is routine practice to replace the filter drier during system maintenance. Replacement filter driers are available that are compatible with ISCEON® MO99.

While the system is empty, check and replace any elastomeric seals that may be near the end of their serviceable life. Even if they were not previously leaking, the change of swell characteristics when changing to any new refrigerant (e.g., R22 to any HFC refrigerant) and the general disturbance to the system may cause worn seals to leak after retrofit. Although, in general, the same seal materials can be used with ISCEON® MO99 it has been observed as with other HFC based refrigerants that shrinkage of the original seal may occur after conversion causing refrigerant leakage (refer to the DuPont bulletin on HFC Compatibility with Elastomeric Seals #K-17335). Critical components commonly affected are Schrader core seals, liquid level receiver gaskets, solenoid valves, ball valves and flange seals but all external seals in contact with the refrigerant should be viewed as a potential leak source post retrofit. Field experience has shown that the older the system, the greater the likelihood of seal and gasket leaks. It is recommended to change any system critical seals (e.g., those which require removal of the refrigerant charge to allow seal replacement e.g., liquid receiver, condenser system) as a matter of course and to have spare seals for other components available during the retrofit should any seal failure occur Schrader valves can generally be changed in-situ, under pressure, using a special tool, and thus are not considered to be system critical. A rigorous leak check regime pre and post retrofit will minimize any refrigerant losses.

4. Evacuate system and check for leaks. Use normal service practices. To remove air or other non-condensables and any residual moisture from the system, evacuate the system to near full vacuum (29.9 in Hg vacuum [500 microns] or less than 0.1 kPa absolute), isolate the vacuum pump from the system and observe the vacuum reading. If the system does not maintain vacuum it is an indication that there might be a leak. Pressurise the system with nitrogen taking care not to exceed the system design maximum pressure and check for leaks. Do not use mixtures of air and refrigerant under pressure to check for leaks; these mixtures can be combustible. After leak checking with Nitrogen remove residual Nitrogen using a vacuum pump.

5 Charge with ISCEON® MO99. Remove liquid only from charging cylinder. (If the cylinder does not have a valve with a dip-tube invert the cylinder so that the valve is underneath the cylinder). The proper cylinder position for liquid removal is often indicated by arrows on the cylinder and cylinder box. Once Liquid is removed from the cylinder, the refrigerant can be allowed to enter the refrigeration system as liquid or vapor as desired. Use the manifold gauges or a throttling valve to flash the liquid to vapor if required.

WARNING: Do not charge liquid refrigerant into the compressor. The presence of liquid refrigerant in a compressor at any time will cause serious irreversible damage!

In general, the refrigeration system will require less weight of the ISCEON® MO99 than of the original R22 charge, although some will require slightly more. The optimum charge will vary depending on the system design and operating conditions. The initial charge amount should be approximately 85% of the standard charge for R22. The final charge amount will usually be approximately 95%.

Note: For systems with a liquid refrigerant receiver charge the system to the normal refrigerant level in the receiver. These values apply provided no changes to mechanical components of the system (which could significantly affect the system's internal volumetric capacity) will be made during the retrofit.

6. Start up system, adjust charge size (for systems without a liquid receiver).

Start the system and let conditions stabilize. If the system is undercharged (as indicated by the level of superheat at the evaporator exit, or by the amount of sub-cool at the

condenser exit) add more ISCEON® MO99 in small amounts (still by transferring as liquid from the charging cylinder) until the system conditions reach the desired level. See the pressure-temperature charts in this bulletin to compare pressures and temperatures in order to calculate superheat or sub-cooling for the refrigerant you are using. Sight glasses in the liquid line can be used in most cases as a guide to system charge, but correct system charge must be determined by measuring system operating conditions (discharge and suction pressures, suction line temperature, compressor motor amps, superheat, etc.). Attempting to charge until the sight glass is "free of bubbles" may result in overcharging the refrigerant. Please read "How to Determine Suction Pressure, Superheat and Subcool."

Ensuring that the correct compressor suction superheat is set is very important for reliable system operation with ISCEON® MO99. Experience has shown that superheat (at the compressor inlet) for ISCEON® MO99 should be the same as for the refrigerant being replaced.

WARNING: Liquid refrigerant entering the compressor at any time during system operation can lead to compressor oil level problems and rapid compressor failure.

7. Monitor oil levels.

During initial operation of the system it is very important to monitor the level of oil in the compressor (or compressor oil management system) to verify that oil is returning to the compressor in an adequate manner.

- If the oil level falls below the minimum allowed level, top up to the minimum level with the existing oil type. Do not fill to the maximum level as the level may rise again.
- Should the oil return appear to be erratic as evidenced by large swings in oil level during the refrigeration system cycle it is recommended that some of the oil be removed from the system and replaced with POE oil. Replacement of up to 30% of the oil with POE will help to restore oil return stability. The exact amount of oil to be changed will depend on the system itself (evaporating temperatures, physical geometry, etc.)
- POE lubricant should be progressively added to the system. An initial addition of 10 – 20% (of the total oil charge) should be made. This should be followed by

small increments until the oil level returns to normal consistently throughout the refrigeration system operating cycle.

- It is important to ensure that, when adding POE oil to the system, the oil level (immediately after addition) is kept below the system mid-point (e.g. mid-sight glass) oil level.

8. **Label the system** to clearly and permanently show the refrigerant in the system and any oil(s) present in the system. It is most important that the change in refrigerant and any other component (including lubricating oil) changes be registered in the system documentation (log book).

IMPORTANT: Thoroughly leak check the system. As mentioned in step 3 it is possible that refrigerant leakage can occur during or immediately after a retrofit. Experience has shown that some leaks will not appear until after the new refrigerant has been charged to the system. Pay particular attention to Schrader valve core seals, solenoid valves and ball valve stems on the liquid high-pressure side.

Pressure/Temperature Charts

How to Read the Pressure/Temperature Chart

The following pages contain pressure/temperature charts for the refrigerants discussed in this bulletin. Three temperatures are shown at a given pressure:

- Saturated Liquid Temperature (Bubble Point)—In the condenser, this is the temperature at which the last bit of vapor has condensed. Below this temperature, the refrigerant will be subcooled liquid. This temperature should also be used when determining the pressure/temperature value of product stored in a refrigerant cylinder.
- Saturated Vapor Temperature (Dew Point)—In the evaporator, this is the temperature at which the last drop of liquid has just boiled. Above this temperature, the refrigerant will be superheated vapor.
- Average Coil Temperature (for ISCEON[®] MO99)—The evaporator and condenser will perform as if it is operating at this constant temperature. It is an average of the bubble and dew point temperatures determined from either the suction or condenser pressure. Use this average temperature to compare coil temperatures with the refrigerant you are replacing. **Note:** this is an

approximation of the average temperature for low glide refrigerants.

How to Determine Suction Pressure, Superheat, and Subcool

Suction Pressure

Determine the expected evaporator temperature using the R22 (from the baseline data you collected prior to the retrofit). Find the same expected evaporator temperature in the Average Coil Temperature column for ISCEON[®] MO99. Note the corresponding pressure for this temperature. This is the approximate suction pressure at which the system should operate.

Superheat

Using the saturated vapor pressure tables for ISCEON[®] MO99, determine the saturated vapor temperature (dew point) for the measured suction pressure. Measure the temperature at the compressor inlet (suction) and subtract the previously determined dew point temperature for ISCEON MO99 to give the amount of vapor superheat.

Subcool

Using the saturated liquid pressure tables for ISCEON[®] MO99, determine the saturated liquid temperature (bubble point) for the measured condensing pressure (usually the high-side pressure). Measure the refrigerant liquid line temperature and subtract it from the previously determined bubble point temperature for ISCEON[®] MO99 to give the amount of liquid subcool.

Retrofit Checklists for Converting HCFC Systems to DuPont™ ISCEON® MO99

Retrofit Guidelines for DuPont™ ISCEON® MO99 Refrigerant

Retrofit Check List: 1) Pre- and Post- Retrofit Checks

Pre-Retrofit Advance Preparation for Retrofit	Check Complete
1 Ensure the Retrofit Procedure has been read Clarify any doubts with DuPont Technical Services	<input style="width: 100%; height: 20px;" type="checkbox"/>
2 Check Service History log-book Recent refrigerant additions might signify system leaks Is current system design in agreement with log-book?	<input style="width: 100%; height: 20px;" type="checkbox"/>
3 Leak check system If leaks found schedule repair	<input style="width: 100%; height: 20px;" type="checkbox"/>
4 Check compressor oil management system design If no oil separator present oil level observation needed after retrofit	<input style="width: 100%; height: 20px;" type="checkbox"/>
5 System performance check: complete data sheet See Retrofit procedure p. 8 If obvious performance problem: Correct before retrofit (or plan to do it during retrofit)	<input style="width: 100%; height: 20px;" type="checkbox"/>
6 Identify system critical elastomeric seals See Retrofit Guidelines p.2	<input style="width: 100%; height: 20px;" type="checkbox"/>
7 Check Compressor oil condition If doubtful schedule change	<input style="width: 100%; height: 20px;" type="checkbox"/>
8 Ensure all needed materials will be available Seals, filter cores, etc. Recovery cylinder(s) Recovery machine, vacuum pump, Nitrogen Technical data: Retrofit Guidelines, PT data (Slide rules, etc.)	<input style="width: 100%; height: 20px;" type="checkbox"/>

Post-Retrofit Verification of system performance and integrity	Check Complete			
	24 hrs	48 hrs	72hrs	1 week
1 Observe compressor oil level Correct if needed (see Guidelines p 3)	<input style="width: 100%; height: 20px;" type="checkbox"/>			
2 Measure Performance Data Use Data Sheet	<input style="width: 100%; height: 20px;" type="checkbox"/>			
3 Carry out Leak check Correct any leaks found	<input style="width: 100%; height: 20px;" type="checkbox"/>			

Retrofit Guidelines for
DuPont™ ISCEON® MO99 Refrigerant

Retrofit Check List: 2) Retrofit Progress Checks

Retrofit Steps	Check Complete
1 Recover old refrigerant using good refrigeration practice Use dedicated recovery cylinder(s) Weigh the recovered refrigerant De-gas the compressor oil using a vacuum pump	<input type="checkbox"/>
2 Break the vacuum using dry nitrogen Minimise ingress of moist air into the system	<input type="checkbox"/>
4 Change necessary mechanical components Filter/dryer Identified system critical elastomeric seals Replace oil if needed	<input type="checkbox"/>
5 Evacuate system. Hold under vacuum. To remove moisture. Early indication of leaks (if vacuum does not hold)	<input type="checkbox"/>
6 If indication of leak pressurise with Nitrogen. Locate leak(s). De-pressurise and correct Evacuate system. Hold under vacuum	<input type="checkbox"/>
7 Charge with ISCEON®MO99 from liquid phase a) If system receiver - to normal level b) If no receiver - initial 90% of R22 charge (See text for values for other refrigerants)	<input type="checkbox"/>
8 Start system, measure performance data (See data sheet) Adjust refrigerant charge if needed Adjust superheat setting if needed	<input type="checkbox"/>
10 Check Compressor oil levels Adjust if necessary	<input type="checkbox"/>
11 Re-check system for refrigerant leaks	<input type="checkbox"/>
12 Label System Refrigerant (and any added/changed oil) Update log-book	<input type="checkbox"/>

System Data Sheet

Type of System/Location: _____

Equipment Mfg.: _____ Compressor Mfg.: _____

Model No.: _____ Model No.: _____

Serial No.: _____ Serial No.: _____

Date of Manufacture _____ Date of manufacture _____

Refrigerant Charge Size: _____ Lubricant Type: _____

Lubricant Type/Charge Size: _____ Drier Mfg./ Model _____

Drier Type (check one): Loose Fill: _____
 Solid Core: _____

Condenser Cooling Medium (air/water): _____

Expansion Device (check one): Capillary Tube: _____ TXV: _____ Electronic _____

Expansion valve: Manufacturer: _____ Model No: _____

Control/Set Point: _____

Location of Sensor: _____

Other System Controls (ex.: head press control), Describe: _____

Performance Data (circle units used where applicable)

Date/Time Refrigerant Charge Size (kg) Ambient Temp. (°C) Compressor: Suction T (°C) Suction P (kPa) Discharge T (°C) Discharge P (kPa) Evaporator: Coil Air/H ₂ O In T (°C) Coil Air/H ₂ O Out T (°C) Operating Service Temperature) (°C) Condenser: Coil Air/H ₂ O In T (°C) Coil Air/H ₂ O Out T (/°C) Superheat and Sub-Cool (derived values) Refrigerant T at Superheat Ctl. Pt (°C) Calculated Superheat (K) Exp. Device Inlet T (°C) Calculated sub-cool (K) Motor Amps (if pack: total) Comments:					
---	--	--	--	--	--

Table 2
Physical Properties of DuPont™ ISCEON® MO99

Physical Property	Unit	ISCEON® MO99	R22
Boiling Point (1 atm.)	°C	-42	-41
Vapor Pressure at 25°C	kPa absolute	1215	1041
Liquid Density at 25°C	kg/m ³	1145	1193
Density, Satd. Vapor at 25°C	kg/m ³	47.8	44.9
Ozone Depletion Potential	CFC11 = 1.0	0	0.05
Global Warming Potential	CO ₂ = 1	2105*	1700

*Source: IPCC Third Assessment Report: Climate Change 2001. GWP value from IPCC Second Assessment Report: Climate Change 1995 = 1835

Table 3
Composition of ISCEON® MO99 (Wt. %)

	R32	HFC125	HFC134a	butane	Iso-pentane
ISCEON® MO99	8.5	45.0	44.2	1.7	0.6

Appendix

Table 4

Pressure – Temperature Chart (SI Units): R22 and ISCEON® MO99

Pressure / bar.g	R22 Saturated Temperature /°C	ISCEON® MO99 Saturated Liquid Temperature /°C	ISCEON® MO99 Saturated Vapor Temperature /°C	ISCEON® MO99 Average Coil Temperature /°C	Pressure / bar.g	R22 Saturated Temperature /°C	ISCEON® MO99 Saturated Liquid Temperature /°C	ISCEON® MO99 Saturated Vapor Temperature /°C	ISCEON® MO99 Average Coil Temperature /°C
-0.7	-63.1	-64.3	-57.3	-60.8	3.4	-3.7	-5.6	0.2	-2.7
-0.6	-58.3	-59.5	-52.6	-56.1	3.5	-3.0	-5.0	0.9	-2.1
-0.5	-54.4	-55.7	-48.8	-52.2	3.6	-2.3	-4.3	1.5	-1.4
-0.4	-51.0	-52.3	-45.5	-48.9	3.7	-1.7	-3.7	2.1	-0.8
-0.3	-48.0	-49.4	-42.6	-46.0	3.8	-1.0	-3.0	2.7	-0.2
-0.2	-45.4	-46.8	-40.1	-43.4	3.9	-0.4	-2.4	3.3	0.5
-0.1	-43.0	-44.4	-37.8	-41.1	4.0	0.2	-1.8	3.9	1.1
0.0	-40.8	-42.3	-35.6	-39.0	4.2	1.4	-0.6	5.1	2.2
0.1	-38.8	-40.3	-33.7	-37.0	4.4	2.6	0.5	6.2	3.4
0.2	-36.9	-38.4	-31.9	-35.1	4.6	3.7	1.7	7.3	4.5
0.3	-35.1	-36.7	-30.1	-33.4	4.8	4.8	2.8	8.4	5.6
0.4	-33.5	-35.0	-28.5	-31.8	5.0	5.9	3.8	9.4	6.6
0.5	-31.9	-33.5	-27.0	-30.2	5.2	7.0	4.9	10.4	7.7
0.6	-30.4	-32.0	-25.6	-28.8	5.4	8.0	5.9	11.4	8.7
0.7	-28.9	-30.6	-24.2	-27.4	5.6	9.0	6.9	12.4	9.6
0.8	-27.6	-29.2	-22.9	-26.0	5.8	10.0	7.9	13.3	10.6
0.9	-26.3	-27.9	-21.6	-24.8	6.0	11.0	8.8	14.3	11.5
1.0	-25.0	-26.7	-20.4	-23.5	6.2	11.9	9.7	15.2	12.5
1.1	-23.8	-25.5	-19.2	-22.4	6.4	12.9	10.6	16.1	13.4
1.2	-22.6	-24.3	-18.1	-21.2	6.6	13.8	11.5	16.9	14.2
1.3	-21.5	-23.2	-17.0	-20.1	6.8	14.6	12.4	17.8	15.1
1.4	-20.4	-22.2	-15.9	-19.1	7.0	15.5	13.3	18.6	15.9
1.5	-19.4	-21.1	-14.9	-18.0	7.2	16.4	14.1	19.4	16.8
1.6	-18.3	-20.1	-13.9	-17.0	7.4	17.2	15.0	20.2	17.6
1.7	-17.4	-19.1	-13.0	-16.1	7.6	18.0	15.8	21.0	18.4
1.8	-16.4	-18.2	-12.1	-15.1	7.8	18.9	16.6	21.8	19.2
1.9	-15.5	-17.3	-11.1	-14.2	8.0	19.7	17.4	22.6	20.0
2.0	-14.5	-16.4	-10.3	-13.3	8.2	20.4	18.1	23.3	20.7
2.1	-13.6	-15.5	-9.4	-12.4	8.4	21.2	18.9	24.1	21.5
2.2	-12.8	-14.6	-8.6	-11.6	8.6	22.0	19.6	24.8	22.2
2.3	-11.9	-13.8	-7.7	-10.8	8.8	22.7	20.4	25.5	22.9
2.4	-11.1	-13.0	-6.9	-9.9	9.0	23.5	21.1	26.2	23.7
2.5	-10.3	-12.2	-6.2	-9.2	9.5	25.3	22.9	27.9	25.4
2.6	-9.5	-11.4	-5.4	-8.4	10.0	27.0	24.6	29.6	27.1
2.7	-8.7	-10.6	-4.6	-7.6	10.5	28.7	26.2	31.2	28.7
2.8	-7.9	-9.9	-3.9	-6.9	11.0	30.3	27.8	32.7	30.3
2.9	-7.2	-9.1	-3.2	-6.2	11.5	31.9	29.4	34.2	31.8
3.0	-6.5	-8.4	-2.5	-5.4	12.0	33.4	30.9	35.7	33.3
3.1	-5.7	-7.7	-1.8	-4.7	12.5	34.9	32.4	37.1	34.7
3.2	-5.0	-7.0	-1.1	-4.0	13.0	36.3	33.8	38.5	36.1
3.3	-4.3	-6.3	-0.4	-3.4	13.5	37.8	35.2	39.8	37.5
					14.0	39.1	36.5	41.1	38.8

Pressure / bar.g	R22 Saturated Temperature / °C	ISCEON® MO99 Saturated Liquid Temperature / °C	ISCEON® MO99 Saturated Vapor Temperature / °C	ISCEON® MO99 Average Coil Temperature / °C
14.5	40.5	37.9	42.4	40.1
15.0	41.8	39.1	43.6	41.4
15.5	43.1	40.4	44.8	42.6
16.0	44.3	41.6	46.0	43.8
16.5	45.5	42.8	47.1	45.0
17.0	46.7	44.0	48.3	46.1
17.5	47.9	45.2	49.4	47.3
18.0	49.1	46.3	50.5	48.4
18.5	50.2	47.4	51.5	49.5
19.0	51.3	48.5	52.6	50.5
19.5	52.4	49.6	53.6	51.6
20.0	53.5	50.6	54.6	52.6
20.5	54.5	51.7	55.6	53.6
21.0	55.5	52.7	56.5	54.6
21.5	56.6	53.7	57.5	55.6
22.0	57.6	54.7	58.4	56.5
22.5	58.5	55.6	59.3	57.5
23.0	59.5	56.6	60.2	58.4
23.5	60.5	57.5	61.1	59.3
24.0	61.4	58.4	62.0	60.2
24.5	62.3	59.4	62.8	61.1
25.0	63.2	60.2	63.7	62.0
25.5	64.1	61.1	64.5	62.8
26.0	65.0	62.0	65.3	63.7
26.5	65.9	62.9	66.1	64.5
27.0	66.7	63.7	66.9	65.3
27.5	67.6	64.5	67.7	66.1
28.0	68.4	65.4	68.5	66.9
28.5	69.2	66.2	69.2	67.7
29.0	70.1	67.0	70.0	68.5
29.5	70.9	67.8	70.7	69.2
30.0	71.7	68.6	71.4	70.0
30.5	72.5	69.3	72.1	70.7
31.0	73.2	70.1	72.8	71.5
31.5	74.0	70.9	73.5	72.2
32.0	74.8	71.6	74.2	72.9
32.5	75.5	72.4	74.9	73.6
33.0	76.2	73.1	75.5	74.3
33.5	77.0	73.8	76.2	75.0
34.0	77.7	74.5	76.8	75.7
34.5	78.4	75.2	77.5	76.4
35.0	79.1	75.9	78.1	77.0

Note: Saturated Liquid Temperature = Bubble Point
Saturated Vapor Temperature = Dew Point

For more information and to find the location of your nearest DuPont ISCEON® refrigerants supplier please contact: www.isceon.com/uk

Europe, Middle East, Africa Regional Office

Du Pont de Nemours International S.A.
2 Chemin du Pavillon
P.O. Box 50
CH-1218 Le Grand-Saconnex
Geneva, Switzerland
Phone: (+41) 22 717 5111
Fax: (+41) 22 717 6169

Czech Republic

Du Pont CZ s.r.o.
Pekarska 628/14
155 00 Praha 5 Jinonice
Phone: (+420) 257 414 111
Fax: (+420) 257 414 150

Germany

DuPont de Nemours (Deutschland) GmbH
Hugenottenallee 173-175
63263 Neu-Isenburg
Tel: (+49) 6102 18 1312
Fax: (+49) 6102 18 1318

Hungary

Du Pont Hungary Ltd.
Neumann Janos street nr.II. floor
H-2040 Budaors
Phone: (+36) 23 509 400
Fax: (+36) 23 509 432

Spain

Du Pont Iberica SA
Av. Diagonal 561
08029 Barcelona
Phone: (+34) 93 227 6171
Fax: (+34) 93 227 6215

Turkey

Du Pont Products SA
Buyukdere Caddesi, Ozsezen Is Merkezi
Esentepe 80280
Istanbul
Phone: (+90) 212 340 0 400
Fax: (+90) 212 340 0 4

Poland

Du Pont Poland Sp z.o.o.
Ul Powzakowska 44c
PL-01-797 Warszawa
Phone: (+48) 22 320 0900
Fax: (+48) 22 320 0901

Russia

Du Pont Russia LLC
Ul. Krylatskaya, 17/3
121614 Moscow
Phone: +7 (495) 797 22 00/06
Fax: +7 (495) 797 22 01

Ukraine

Du Pont de Nemours International S.A.
Representative office – Ukraine
Business center “Podil Plaza”
30/A, Spaska St. – Kyiv, 04070
Phone: (+38) 044 495 26 70
Fax: (+38) 044 495 26 71

United Kingdom

Du Pont (UK) Limited
Wedgwood Way
Stevenage
Hertfordshire. SG1 4QN
Phone: (+44) 438 734000
Fax: (+44) 1438 734065

Copyright © 2008 DuPont or its affiliates. All rights reserved. The DuPont Oval Logo, DuPont™, The miracles of science™, and ISCEON®, are registered trademarks or trademarks of E. I. du Pont de Nemours and Company or its affiliates.

NO PART OF THIS MATERIAL MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED IN ANY FORM OR BY ANY MEANS ELECTRONIC, MECHANICAL, PHOTOCOPYING, RECORDING OR OTHERWISE WITHOUT PERMISSION OF DUPONT.

The information set forth herein is furnished free of charge and is based on technical data that DuPont believes to be reliable. It is intended for use by persons having technical skill, at their own discretion and risk. The handling precaution information contained herein is given with the understanding that those using it will satisfy themselves that their particular conditions of use present no health or safety hazards. Because conditions of product use are outside our control, we make no warranties, express or implied, and assume no liability in connection with any use of this information. As with any material, evaluation of any compound under end-use conditions prior to specification is essential. Nothing herein is to be taken as a license to operate under or a recommendation to infringe any patents.